

# TABLE OF CONTENTS

	Page
<b>1.0 Introduction .....</b>	<b>1</b>
<b>2.0 Definitions .....</b>	<b>2</b>
<b>3.0 Electric Services Available .....</b>	<b>3</b>
<b>4.0 General Requirements .....</b>	<b>3</b>
4.01 Application for Electric Service .....	3
4.02 Extension of Company's Facilities .....	3
4.03 Requirements for a Residential Structure to be Considered a Permanent Installation .....	3
4.04 Installation and Responsibility .....	4
4.05 Customer Alterations and Additions .....	4
4.06 Requirements of Electrical Inspection .....	4
4.07 Swimming Pool Location .....	5
4.08 Structures Near Overhead Lines .....	5
4.09 Attachments on Company-Owned Facilities .....	5
4.10 Requested Protection for Persons Working Near Company Facilities .....	5
4.11 Access to Customer's Premises .....	5
4.12 Company's Equipment on Customer's Premises .....	5
4.13 Company's Responsibility .....	5
4.14 Right to Refuse or Discontinue Service .....	5
4.15 Stand-by Generator Service .....	6
4.16 Transformer Vaults .....	6
<b>5.0 Overhead Service Requirements (600 Volts or Less) .....</b>	<b>6</b>
5.01 General .....	6
5.02 Service Drop .....	6
5.03 Service Entrance .....	7
5.04 Connections Between Company's & Customer's Facilities .....	7
5.05 Permanent Overhead Service Installations .....	8
5.06 Temporary Overhead Service Installations .....	8
5.07 Mobile/Manufactured Home Overhead Service Installations .....	8
5.08 Central Distribution Service Installations (Farm Pole) .....	8
5.09 Overhead Services in Excess of 600 Volts .....	8
<b>6.0 Underground Service Requirements (600 Volts or Less) .....</b>	<b>9</b>
6.01 General .....	9
6.02 Service Lateral (Residential) .....	9
6.03 Service Lateral (Commercial or Industrial) .....	10
6.04 Service Entrance .....	11
6.05 Connections Between Company's & Customer's Facilities .....	11
6.06 Permanent Underground Service Installation .....	11
6.07 Temporary Underground Service Installation .....	11
6.08 Mobile/Manufactured Home Underground Service Installation .....	11
6.09 Underground Service Installations in Excess of 600 Volts .....	12
6.10 Excavation Near Utility Underground Facilities .....	12

<b>7.0</b>	<b>Customer Equipment .....</b>	<b>13</b>
7.01	General .....	13
7.02	Motor Installations .....	13
7.03	Required Equipment Protection .....	13
7.04	Air Conditioners, Central Space Heating, Heat Pumps Including Supplemental Heating Elements in Heat Pumps .....	14
7.05	Electric Water Heaters .....	14
7.06	Electric Welding, X-ray, Radio, Electronic Equipment, etc. ....	14
7.07	Lightning and Surge Protection .....	14
7.08	Three-phase Converter .....	14
<b>8.0</b>	<b>Meter Installations .....</b>	<b>15</b>
8.01	General .....	15
8.02	Meter Locations .....	15
8.03	Meter Relocations .....	15
8.04	Emergency Meter Removal .....	15
8.05	Group Meter Installation .....	15
8.06	Transformer-Rated Meter Installations .....	16
8.07	Transformer-Rated Metering at Pad-Mounted Transformer .....	16
8.08	Metering Communications .....	16
8.09	Seals .....	17
<b>9.0</b>	<b>Meter Sockets .....</b>	<b>17</b>
9.01	General .....	17
9.02	Company-Furnished Meter Sockets .....	17
9.03	Customer-Furnished Meter Sockets .....	18
9.04	Meter Socket Repairs/Replacements .....	18
9.05	Meter Socket Specifications .....	18
	<b>Fax Applications for New Electric Service</b>	
	Fax Cover Sheet .....	61
	Fax Application (Residential) .....	63
	Fax Application (Non-Residential) .....	65

# APPENDIX: SERVICE AND METER INSTALLATION SPECIFICATION

## Overhead Service Installation 600 Volts or Less

Figure 1	Service Drop Clearance Minimums for Services Under 600 Volts .....	23
Figure 2	Typical Grounding Details .....	24
Figure 3	Typical 320 AMP or Less Overhead Service Installation .....	25
Figure 4	Temporary Overhead Service Support .....	26
Figure 5	Typical Overhead Service for Individually Located Mobile Homes .....	27
Figure 6	Pole Mounted Self-Contained Meter Not Exceeding 320 AMPS, Customer Central Distribution Service .....	28
Figure 7	Pole Mounted Self Contained Meter Not Exceeding 320 AMPS, Customer Central Distribution Service with Stand-by Generator Facilities .....	29
Figure 8	Stand-by Generator for 120/240 Volt Single-Phase Service (Customer-owned) .....	30
Figure 9	Typical Overhead Service Installation, Building Attachment, 3-Phase, 4-Wire Service .....	31
Figure 10	Connecting Multiple Services .....	32
Figure 11	Pole Mounted Transformer-Rated Metering (Customer-Owned Pole) .....	33

## Underground Service Installations 600 Volts or Less

Figure 20	Typical 320 AMP or Less Underground Service Installation .....	35
Figure 21	Typical Underground Mobile Home Service for Parks or Individually Located Homes .....	36
Figure 22	Temporary Underground Service Support at Transformer .....	37
Figure 23	Underground Transformer-Rated Metering Installation (3-Phase, 4-Wire Service) .....	38
Figure 24	Typical Transformer-Rated Metering Installation at Pad-Mounted Transformer (3-Phase, 4-Wire Service) .....	39
Figure 25	Clearance Requirements from Buildings for Pad-Mounted Transformer .....	40
Figure 26	Clearances of Pad-Mounted Equipment from Shrubs, Plants and Other Obstructions .....	41
Figure 27	Vehicular Barrier for Pad-Mounted Equipment .....	42
Figure 28	Concrete Pad Foundation Pad-Mounted Transformer 75 to 500 KVA, 3-phase, 12.5 & 34.5 KV High Side .....	43
Figure 29	Concrete Pad Foundation Pad-Mounted Transformer 750 to 2500 KVA, 3-phase, 12.5 & 34.5 KV High Side .....	44
Figure 30	Concrete Pad Foundation Pad-Mounted Transformer General Notes .....	45
Figure 31	Pad Foundation Pad-Mounted Transformer Single Phase .....	46

## Meter Location and Installation

Figure 40	Residential Service-Meter Location .....	48
Figure 41	Self-Contained Meter Socket Connections .....	49
Figure 42	Self-Contained Meter Installation 480/277 Volt, 3-Phase, 4-Wire .....	50
Figure 43	Multiple Metering Installations 480Y/277 Volt .....	51
Figure 44	Multiple Meter Installation 240 Volts or Less .....	52
Figure 45	Pre-Assembled Multiple Meter Installation .....	53
Figure 46	Wiring Trough Installation with Metering Transformer Cabinet .....	54
Figure 47	Typical Transformer-Rated Metering Installation Cabinet-Mount, Single-Phase, 120/240 Volt or 120/208 Volt .....	55
Figure 48	Typical Transformer-Rated Metering Installation Cabinet-Mount, 3-phase, 240/120 Volt Delta or 208/120 Volt Wye .....	56
Figure 49	Typical Transformer-Rated Metering Installation Cabinet-Mount, 3-phase, 480/277 Volt Wye .....	57
Figure 50	Typical Transformer-Rated Metering Installation 600 Volts or Less – Outdoor Overhead .....	58